Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622241.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: 914114
SAMPLE LOCATION: GIRL'S BATHROOM

DATE SAMPLED: 6/22/2017 TIME SAMPLED: 08:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.4	ug/l	15	6/26/17-12:28
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622239.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: 914112
SAMPLE LOCATION: GYM

DATE SAMPLED: 6/22/2017 TIME SAMPLED: 08:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	6/26/17-12:22
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622244.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: FIELD BLANK
SAMPLE LOCATION:

DATE SAMPLED: 6/22/2017 TIME SAMPLED:

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	6/26/17-12:36
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622243.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: 914117
SAMPLE LOCATION: STAFF/BOY'S BATHROOM

DATE SAMPLED: 6/22/2017 TIME SAMPLED: 08:07

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	6/26/17-12:33
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622242.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: 914115
SAMPLE LOCATION: KITCHEN

DATE SAMPLED: 6/22/2017 TIME SAMPLED: 08:06

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	6/26/17-12:30
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370622240.0
CLIENT # LOR21
DATE SUBMITTED: 6/22/2017

TO: Lord Stirling School
90 Lord Stirling Road
PO Box 369
Basking Ridge NJ 07920
ATT: Wendi Smith

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID: 914113
SAMPLE LOCATION: CAFE

DATE SAMPLED: 6/22/2017 TIME SAMPLED: 08:03

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	6/26/17-12:25
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

309418

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.